

MANUAL - LIST OF BACNET OBJECTS

Advantage Advantage Digital VAV Diffusers



v001 – Issue Date: 12/29/21 © 2021 Acutherm. All rights reserved.

TABLE OF CONTENTS

Overview

List of BACnet Objects 1

BACNet List

BACnet Points List for Advantage2

SUPPORT **V**

Having difficulty installing this product? Acutherm is here to help.

Application Support

510.785.0510 techsupport@acutherm.com acutherm.com

OVERVIEW

List of BACnet Objects

The different properties of the diffuser may be accessed using a LCD thermostat (or Setup Tool) and over the BACnet network. Below is a summary of the BACnet Objects followed by a detailed description of each Object. Some properties are only accessible through the thermostat and others only over the BACnet network. Properties accessible by both are indicated below.

BACnet Network Addressing

The BACnet MAC Address can be set using the LCD thermostat or the dip switches located on the diffuser (see diffuser Installation manual for more details).

The BACnet Instance (or ID) Number can only be set using the LCD thermostat (see diffuser Installation manual for more details).

BACnet Objects Summary

Measurements Al1* Room Temperature Al3* Supply Air Temperature

Set Points

AV6* Current Room Setpoint AV4* Room Setpoint Low Limit AV5* Room Setpoint High Limit AV7* Night Heat Setpoint AV8* Night Cool Setpoint

Damper Position

AV18* Current Damper Position AV12* Unoccupied (Night) Damper Position AV19* Damper Target AV20 Damper Neutral Supply Position AV21* Damper Cool Min Position AV22* Damper Cool Max Position AV23* Damper Heat Min Position AV24* Damper Heat Max Position

Overrides

AV25* Damper Override (Remote Mode Flag) AV28 Net Setpoint AV29 Net Room Temperature AV30 Net Occupancy

Heat Cool Mode

AV14* Room Load (Controller Status)

Special with Wireless Thermostat

Al8 Wireless Signal Strength Al9 Wireless Batter Code

Special with CO²/Humidity Thermostat Al10* Room CO² Al11* Room Humidity

Special with Occupancy Thermostat

AV2 Occupancy AV3* Occupancy Source

Special with DMS Flow Measurement

AV41* Measured airflow AV42* Calibration K-Factor AV43 Airflow connection status AV44* Airflow units of measure

Special Applications

Al4 to Al7 Analog Inputs AV27 Aux Analog Output Voltage

AV9 Binary Output Application AV10 Binary Output Signal Type AV11 Binary Output Status

AV31 Net Lights

AV33 Contact Closure One Application AV34 Contact Closure One Status AV35 Contact Closure Two Application AV36 Contact Closure Two Status AV37 Contact Closure Three Application AV38 Contact Closure Three Status AV39 Contact Closure Four Application AV40 Contact Closure Four Status

Controller Properties – DO NOT ADJUST WITHOUT APPROVAL

AV1* Control Model AV15* Proportional Band AV16* Day Differential AV17* Inlet Size AV26 Drone Output Voltage AV32 Power Frequency AV13 Ping AV45 Reserved for manufacturer

*Also available through LCD thermostat

BACNET LIST

BACnet Points List for Advantage (3.0.5 Rev A 1027v)

Object	Name	Units	Default	Range	Description	R/W	RETAINED ON POWER FAILURE
Al1	Room Temperature	°F/°C	N/A	(-59) - 300	Current Room Temperature	R	N
Al2	N/A	N/A	0	0	N/A	R	N
AI3	Supply Air Temperature	°F/°C	N/A	(-59) - 300	Current Supply Air Temperature	R	N
Al4	Analog Input J18	V	N/A	0-10	Spare Analog Input	R	N
Al5	Analog Input 4	V	N/A	0-10	IO Board Al4	R	N
Al6	Analog Input 5	V	N/A	0-10	IO Board Al5	R	N
AI7	Analog Input 6	V	N/A	0-10	IO Board Al6	R	N
AI8	Wireless Signal Strength or N/A	%	N/A	0-100	Signal strength from wireless stat when connected	R	N
Al9	Wireless Battery Code or N/A	N/A	N/A	0-5	Battery code from wireless stat when connected	R	Ν
Al10	Room CO ²	ppm	Dynamic	350-10000	Current CO ² at the T-Stat	R	N
Al11	Room Humidity	%RH	Dynamic	0-100	Current Relative Humidity at the T-Stat	R	N
AV1	Control Model	N/A	N/A	1-3	Source of room temperature set point 2 - Thermostat Setpoint 3 - T-Stat not connected	R	Y
AV2	Occupancy	N/A	N/A	0-1	Occupancy Status 0 - Unoccupied 1 - Occupied	R	N
AV3	Occupancy Source	N/A	N/A	0,4-5, 12, 14-15	Source of occupancy: 0- Occupied Default Mode 2 - Occupied from Contact Closure 3 - Occupied from T-Stat Button Press 4 - Occupied from Motion Sensor 5- Occupied from Network Override (AV30) 12 - Unoccupied from Contact Closure 14- Unoccupied from Motion Sensor 15 - Unoccupied from Network Override	R	N
AV4	Room Setpoint - Low Limit	°F/°C	65°F(18°C)	10-AV5	Lowest user-adjustable setpoint. The upper limit is equal to AV5	R/W	Y
AV5	Room Setpoint - High Limit	°F/°C	80°F(26°C)	AV4-250	Highest user-adjustable setpoint. The lower limit is equal to AV4	R/W	Y
AV6	Room Setpoint	°F/°C	72°F(22°C)	AV4-AV5	Current Room Setpoint (Limited by AV4 and AV5)	R	N
AV7	Night Heat Setpoint	°F/°C	62°F(17°C)	0-249	Setpoint at which controller will enter Heating mode during unoccupied periods (1 degree difference must be between heat and cool to adjust the range). The upper limit is one less than AV8	R/W	Y
AV8	Night Cool Setpoint	°F/°C	83°F(28°C)	1-250	Setpoint at which controller will enter Cooling mode during unoccupied periods (1 degree difference must be between heat and cool to adjust the range). The lower limit is one less than AV7	R/W	Y

BACNET LIST

Object	Name	Units	Default	Range	Description	R/W	RETAINED ON POWER FAILURE
AV9	Binary Output Application	N/A	N/A	0-6	Configuration of the spare binary output: 0 - ON during Heat (Load = Trip Point to +100%) 1 - ON during Cooling (Load = Trip point to -100%) 2 - ON during Heating & Cooling 3 - ON during Deadband (satisfied) (Load = 0% to Trip Point) 4 - Room Lights Control (Motion T-Stat) 5 - Output OFF (override Off) 6 - Output ON (override On)	R/W	Y
AV10	Binary Output Signal Type	N/A	N/A	0-6	Signal Type: 1 - PWM 2 - PDM 3 - On/Off (24VAC on/off to enable relay (by others 12VA max) 4 - PWM, disabled if hot air in duct 5 - PDM, disabled if hot air in duct 6 - On/Off, disabled if hot air in duct 1 and 2 only available if output application is heat. Otherwise only 3 available. Do not use 5 and 6 with duct heater.	R	N
AV11	Binary Output Status	N/A	N/A	N/A	0/1 if on/off. Otherwise 0-100%	R	N
AV12	Unoccupied (Night) Damper Position	%	0	0-100	Position at which the damper is held during unoccupied periods	R/W	Y
AV13	Ping	N/A	0	0-255	Number of times the LCD T-Stat will beep. Useful for locating a box/T-Stat. (For example, if the number 30 is written to this variable, the T-Stat will beep 30 times before zeroing this variable)	R/W	N
AV14	Controller Status	%	N/A	-100% to +100%	Current Room Load (Pl value) 1%-100% = Heating load 0% = Deadband (room satisfied) (-1%) - (-100%) = Cooling Load	R	N
AV15	Proportional Band	°F/°C	2°F(1°C)	1-20	Temperature band through which the PI controller travels through 1% to 100% load	R/W	Y
AV16	Day Differential	°F/°C	1°F(0.5°C)	1-25	Temperature band on either side of the setpoint within the controller is deemed satisfied. (for example, with a Day Differential of 1°F, and a setpoint of 72°F, the controller is satisfied between 71°F and 73°F and Load = 0%)	R/W	Y
AV17	Inlet Size	Inches	8	6, 8, 10, 12	Inlet Size for the Advantage unit.	R/W	Y
AV18	Current Damper Position	%	N/A	0-100, 999	Current damper position in percent, See "damper response chart" Note: A value of 999% indicates the damper is recalibrating itself	R	N
AV19	Damper Target	%	N/A	0-100	Damper target in percent	R	N
AV20	Damper Neutral Supply Position	%	50	0-100	Damper position when supply is neutral	R/W	Y
AV21	Damper Cool Min Position	%	0	0-100	Minimum m damper position in cooling, Upper Limit is AV22	R/W	Y

BACNET LIST

Object	Name	Units	Default	Range	Description	R/W	RETAINED ON POWER FAILURE
AV22	Damper Cool Max Position	%	100	0-100	Maximum damper position in cooling, Lower Limit is AV21	R/W	Y
AV23	Damper Heat Min Position	%	0	0-100	Minimum damper position in heating, Upper Limit is AV24	R/W	Y
AV24	Damper Heat Max Position	%	100	0-100	Maximum damper position in heating, Lower Limit is AV23	R/W	Y
AV25	Remote Mode Flag (Damper Position Override)	N/A	0	0-7	Remote Mode - Damper Override 0 - Automatic control (normal run mode) 1 - Target Cool Min 2 - Target Cool Max 3 - Target Heat Min 4 - Target Heat Max 5 - Target Neutral Airflow 6 - Open Damper 100% 7 - Close Damper (0%)	R/W	N
AV26	Drone Output Voltage	V	N/A	0-10	VDC output to Advantage Drone Units	R	N
AV27	Aux Analog Output Voltage	V	N/A	0-10	Spare Voltage Output (J17)	R	N
AV28	Net Setpoint	°F/°C	0	0-250	Setpoint override from BACnet network	R/W	Y
AV29	Net Room Temp	°F/°C	0	0-250	Room temperature override from BACnet network	R/W	Y
AV30	Net Occupancy	N/A	0	0-2	Occupancy override from BACnet network 0 - Normal Operation 1 - Force Occupied 2 - Force Unoccupied	R/W	Y
AV31	Net Lights	N/A	0	0-2	Room Lights override from BACnet network 0 - Normal Operation 1 - Force Lights On 2 - Force Lights Off	R/W	Y
AV32	Power Frequency	Hz	60	50/60	Device Power Input Frequency 50 - 50 Hz Power Input 60 - 60 Hz Power Input	R/W	Y
AV33	Contact Closure One Application	N/A	0	0-4	Contact Closure Configuration on J14 0 - Not Used 1 - Unoccupied 2 - Occupied 3 - Full Open 4 - Full Close	R/W	Y
AV34	Contact Closure One Status	N/A	0	0-1	The current contact closure configuration on J14 0 - Not Contacted 1 - Contacted	R	N
AV35	Contact Closure Two Application	N/A	0	0-4	Contact Closure Configuration on Al4 0 - Not Used 1 - Unoccupied 2 - Occupied 3 - Full Open 4 - Full Close	R/W	Y
AV36	Contact Closure Two Status	N/A	0	0-1	The current contact closure configuration on Al4 0 - Not Contacted 1 - Contacted	R	N

BACNET LIST

Object	Name	Units	Default	Range	Description	R/W	RETAINED ON POWER FAILURE
AV37	Contact Closure Three Application	N/A	0	0-4	Contact Closure Configuration on Al5 0 - Not Used 1 - Unoccupied 2 - Occupied 3 - Full Open 4 - Full Close	R/W	Y
AV38	Contact Closure Three Status	N/A	0	0-1	The current contact closure configuration on AI5 0 - Not Contacted 1 - Contacted	R	N
AV39	Contact Closure Four Application	N/A	0	0-4	Contact Closure Configuration on Al6 0 - Not Used 1 - Unoccupied 2 - Occupied 3 - Full Open 4 - Full Close	R/W	Y
AV40	Contact Closure Four Status	N/A	0	0-1	The current contact closure configuration on Al6 0 - Not Contacted 1 - Contacted	R	N
AV41	Airflow	CFM or LPS or CMH	0	N/A	The current airflow reading from the airflow sensor.	R	Ν
AV42	K Factor	N/A	890	1-20000	The K Factor used in calculation the device airflow.	R/W	Y
AV43	Airflow Sensor Connection Status	N/A	0	0-1	The connection status of the SDP airflow sensor 0 - Not Connected 1 - Connected	R	N
AV44	Airflow Units	N/A	1	1 - 3	1 - CMF 2 - LPS 3 - CMH	R	N
AV45	Show User Settings	N/A	0	N/A	Reserved for manufacturer	R	N



This document contains the most current product information as of this printing. For the most up-to-date product information please go to acutherm.com, where you can also access digital brochures, CAD files, performance data and more.

Talk to our experts at +1 800 544 1840 Find us at our Acutherm Headquarters 1766 Sabre Street, Hayward, CA 94545, USA Tel: +1 510 785 0510 Fax: +1 510 785 2517 Send your questions to techsupport@acutherm.com

© 2021 Acutherm. All rights reserved.