





TF - Therma-Fuser™ VAV DIFFUSER

Thermal 24" / 600mm Square Plague Diffuser With Blade Dampers





CEILING MODULE:

- □ 24" x 24"
- ☐ 600mm x 600mm

NOMINAL DUCT SIZE:

- ☐ 6" (152mm) ☐ 8" (203mm) □ 10" (254mm)
- □ 12" (305mm)

STANDARDCONSTRUCTION:

STEEL CONSTRUCTION

OPERATION:

- ☐ HC VAV HEATING AND COOLING
- ☐ CW VAV HEATING AND CV HEATING
- ☐ C VAV COOLING ONLY
- ☐ D MANUALLY ADJUSTABLE
- ☐ RA MATCHING RETURN

SETPOINT RANGE:

- ☐ STANDARD RANGE FOR HEATING AND COOLING
 - 70 TO 78°F (21 TO 26°C)
- ☐ HCSP HIGHER COOLING RANGE 74 TO 80°F (23 TO 28°C)
- ☐ LHSP LOWER HEATING RANGE
- 64 TO 73°F (18 TO 23°C)
- ☐ HCLH HIGHER COOLING AND LOWER HEATING

FINISH:

☐ B12 - WHITE

(OPTIONAL FINISHES AVAILABLE)

OPTIONAL MINIMUM FLOW ADJUSTMENT:

- ☐ FR FIXED RUBBER BUMPER, 20% MINIMUM FLOW
- ☐ FS ADJUSTABLE SCREW TYPE, FACTORY SET TO:
 - □ 20% □ 30%


OPTIONAL REMOTE ADJUST:

- ☐ DAM DIGITAL WALL ADJUSTER, MASTER UNIT, INCLUDES ADJUSTER AND 35 FT. (10.7m) CABLE
 - ☐ CPL COVERPLATE TO INSTALL DAM WALL ADJUSTER IN STANDARD 2"x4" (51mm x 102mm) ELECTRICAL BOX
- ☐ WAM WIRELESS WALL ADJUSTER, MASTER UNIT
- \square DA SECONDARY UNIT, RESPONDS TO SIGNAL FROM DAM OR WAM MASTER UNITS
- DAM AND WAM REQUIRE 24VAC POWER INPUT

- \square AFI FIBERGLASS INSULATION WITH FOIL FACING
- ☐ HB HANGER BRACKETS



☐ ARC - PRESSURE RELIEF COLLAR (SHIPPED LOOSE) (ALSO SEE SUBMITTAL 268238)



NOTES:

• FACTORY DEFAULTS:

SET TO 74°F (23°C) WITH STANDARD RANGE COOLING SET TO 80°F (26.5°C) WITH HCSP, HCLH OPTIONS HEATING SET TO 68°F (20°C) WITH LHSP, HCLH OPTIONS

FACTORY TOLERANCE ±1/16" (2mm)

NOTE - METRIC DIMENSIONS HAVE BEEN ROUNDED TO THE NEAREST MILLIMETER

TF PROJECT: SUBMITTAL NO: 268764

VAV DIFFUSER REV 0 **ENGINEER:** W/ BLADE DAMPER

CUSTOMER:

SUBMITTAL DATE:


2017/08/24


© Copyright 2017 SHEET 1 OF 2




TF - Therma-Fuser™ VAV DIFFUSER

Thermal 24" / 600mm Square Plaque Diffuser With Blade Dampers







NOTE - METRIC DIMENSIONS HAVE BEEN ROUNDED TO THE NEAREST MILLIMETER

PROJECT: SUBMITTAL NO: 268764 TF

ENGINEER:

REV 0

VAV DIFFUSER
W/ BLADE DAMPER

CUSTOMER:

SUBMITTAL DATE: 2017/

2017/08/24

© Copyright 2017 SHEET 2 OF 2